



中国认可
国际互认
检测
TESTING
CNAS L0454

Type Test Certificate for Special Equipment (Lift)

Certificate No. TSX B32001420200169

Applicant: Shenyang Bluelight Automatic Technology Co., Ltd.
Registered address of applicant: No.37 Shiji Road, Hunnan New District, Shenyang, Liaoning
Manufacturer: Shenyang Bluelight Automatic Technology Co., Ltd.
Manufacturing address: No.99 Chuangxin 1st Road, Hunnan New District, Shenyang, Liaoning
Category of equipment: Lift major component
Type of equipment: Control cabinet
Name of product: Lift control cabinet
Model of product: SJT-WVF5
Type test report No.: T14-B320-20-169

After type test, this product is accord with TSG T7007-2016 *Regulation for type tests of lifts* and GB 7588-2003+XG1-2015.

Applicable product model of the certificate: SJT-WVF5.

See appendix for application product parameters and configuration of the certificate.

Issue date: 2020-08-14

Review date: before 2022-08-14

NETEC

National Elevator Inspection and Testing Center

Note 1: The applicant has responsibilities to ensure that the products conform to the requirements of the safety technical specifications and relative standards, and to ensure that the products are consistent with the tested sample mentioned above.

Note 2: This certificate is not applicable to lift safety protection component and major component manufactured after the review date.

Appendix

Application Parameters Range and Configuration of Lift control cabinet

Rated speed of the lift	≤4.0m/s	Rated power	≤30kW
Speed control mode	Variable frequency speed control	Control mode	Selective collective control
Location	Partly outside of the well, Partly inside of the well	Applicable environment	Indoor
Applicable type of lifts	Traction drive passenger lift, traction drive goods lift		
Type of control device	Micro-computer		
Model of control device	MU_V61		
Manufacturer of control device	Shenyang Bluelight Automatic Technology Co., Ltd.		
Model of speed control device	BL6-UO40□(□ stands for rated power, which is not more than 30)		
Manufacturer of speed control device	Shenyang Bluelight Automatic Technology Co., Ltd.		
Control of levelling and re-levelling with doors open	Equipped or Unequipped		
Monitoring the normal slowdown of the machine in case of reduced buffer stroke	Unequipped		
Emergency and test operation device	Equipped		
Energy feedback device	Unequipped		
Model of automatic rescue operation device	ARD4S		
Explosion protection grade	/		
Explosion protection type	/		
PESSRAL	Model	/	
	Function	/	
	Manufacturer	/	



Issue date: 2020-08-14

Review date: before 2022-08-14